



TOWN OF STRATFORD

COMMUNITY CAMPUS SITE SERVICING

CONTRACT NO. 222617.00

ADDENDUM NO. 4

April 13, 2023

(To be added to and made part of the Tender Documents)

The following changes or modifications shall be made to the Tender Documents:

TO THE SPECIFICATIONS

Section 00 21 13 Instruction to Tenderers

Page 3 Item 18, delete "Section 01 00 00" and replace with "Section 01 10 10"

Section 00 4143 – Tender Form – Unit Rate

Page 12, Item 6.1, Renumber item 6.6 to item 6.1

Page 12, Item 6.1.1 Delete item description and replace with the following:

1. Source select borrow at site location in lieu of using own borrow source – per cubic meter price.

Section 01 10 10 General Instructions

Add new item 1.23 as follows:

1.23 Equivalents & alternatives

.1 Where any particular brand of manufactured and article is described or specified, it is to be regarded as a standard, but another brand equally as good may be accepted, at the discretion of the Consultant. No change in the Specification will be made prior to the acceptance of the tenders. If the Contractor wishes to make a substitution after the Contract has been awarded, make application, complete with all relevant technical literature from the manufacturer to aid the Consultant in the request, in writing, otherwise the Contractor will be held to the terms of the Specifications. No extra cost will be allowed for approved equivalents.



.2 When the Owner is prepared to permit the use of a brand of manufactured article as an alternative to any specified brand of manufactured article even though such alternative may not be equivalent to that specified, it may be used at the discretion of the Consultant but only after price adjustments have been negotiated and approved by the Consultant.

.3 If the alternative requires modifications, adjustments, or additions to the specified works, submit to the Consultant, drawings and specifications for these modifications, adjustments or additions in the same detail as presented in the Contract. Approval in principle by the Consultant of these modifications, adjustments or additions in no way relieves the Contractor of obligations or liabilities under the Contract to provide for finished piece of work complete and operational in all essentials.

.4 No change or substitution can be made without the written consent of the Consultant.

.5 The Consultant will record the time required to evaluate equivalents and alternates proposed by the Contractor including making changes to the Contract Documents occasioned thereby. Whether or not the Consultant accepts a proposed substitute, reimburse the Owner for the charges of the Consultant for evaluating any proposed substitute.

Section 01 29 00 - Project Particulars & Measurements

Page 5 Item 1.1.13 Fire Hydrant & Valve, subsection .2 This item includes, add "bollards," following "testing, disinfection"

Section 26 90 00 - Instrumentation

Add new item 3.7 as follows:

3.7 SCADA Integration

.1 Arrange and pay for SCADA Integration Services to add this lift station into the Town of Stratford's SCADA system. Provide assistance to the Integrator as required. Belanger Electric is the acceptable integrator.



TO THE DRAWINGS:

Drawing C11 – Plan & Profile Street A - Sta 0+220 to 0+ 300

Clarification to note 3:

Excavate to road, temporary access or pump station access subgrade, remove any remaining root mat. Where the reworked till is divided into two layers, the uppermost layer shall be removed, where reworked till is a single layer, the entire layer shall be removed.

Drawing C27 – Details No. 2

- 1. Detail 8 – Single pipe trench. Add callout bubble to note “rigid insulation where indicated. See detail 14/C27”**

A handwritten signature in cursive script that reads "Tim LeLacheur".

Tim LeLacheur, P.Eng.
CBCL Limited
April 13, 2023